

Comments on GridWise Architecture Council / NIST Home-to-Grid Domain Expert Working Group Requirements

Name: Chris King Company: eMeter Corporation

Please identify the location of each comment by page and line number. Provide your comment and your proposed change, if any.

E/G/T: E = editorial (typo, grammar, clarification), G = general, T = technical

ID = (Company initials)-(comment number); e.g., NIST-1 for first NIST comment; NIST-2 for second NIST comment

Page	Line	E/G/T	ID	Comment	Proposed change	Resolution by subcommittee
10	272	E	eMeter-1	The sentence is confusing.	Clarify the meaning of “from the utility.”	Accepted. Removed this requirement, as proposed by Lawrence Berkeley Labs.
10	272	G	eMeter-2	It would seem an unconstitutional violation of customer privacy to require that the Energy Management Control actually report every override to the utility.	Change to read: The HAN Device shall have the capability, at the customer’s option, to report any customer override of control from an Energy Management Control or directly from the utility	Accepted. See eMeter-1
13	348	G	eMeter-3	Many utilities (e.g. SCE, PG&E, SDG&E, HECO) are proposing Peak Time Rebate rates, so this should be included on the list.	Add a new line item: The application shall calculate a HAN Device value for Peak Time Rebate (PTR).	Accepted. Text added.
14	389	G	eMeter-4	See Comment eMeter-2.	Change to read: Capability to signal any consumer-initiated overrides, at consumer’s option.	Accepted.